



PicoPort Version Info

▶ 11.26.2018

Firmware

- V4.100 release
- Fixed issue in Metasys N2 slave driver where COS notifications stop being sent to the master.
- Fixed delays in Metasys N2 COS reporting on high traffic networks.
- Improved Metasys N2 slave COS checking when the driver is running on multiple ports.

▶ 07.24.2018

Firmware

- V4.000 release
- BACnet BTL Re-Certification changes
 - Made Polarity property writable from the network for Binary Inputs and Binary Outputs.
 - Made the Local Date and Local Time properties of the Device object writable from the network.
 - Added date and time validation and rollover checking for Unix time format
 - Fixed issue where WritePropertyMultiple did not always return the recommended error code for syntax errors that occur after the first property.
- Reworked Modbus RTU Slave driver to allow Coils and Discrete Inputs to be mapped directly to database locations.
- Updated Macurco Modbus Monitor driver to support sensor addresses from 1 - 99 and added support for CD-6H.
- Fixed issue with USB communications where response packets may not always be sent.
- Corrected check in Modbus RTU Slave to return an exception when 16-bit registers and 32-bit registers are accessed in a single request.

Datasheet version

- June 29, 2018

▶ 01.05.2018

Firmware

- V3.200 release
- Added ability to release an object's value to Metasys N2 Master.
- Added ability to release a point's value to Siemens FLN Master.
- Increased configuration file memory by 25 percent.
- Increased object memory by 7 percent.



- Fixed issue where network configuration parameters would be reset when applying a device update file using the Network Parameter Utility.
- Reworked when network configuration parameters are overwritten with values from the configuration file. This behavior is now triggered by the ICC Configuration Studio.
- Changed reset behavior of the network port's RS-485 data enable signal to be consistent with all other UART signals.
- Fixed upper range of TX-6 RD detector for Macurco Modbus Monitor.
- Added validation checks for Macurco Modbus Monitor baud rate and parity network parameters.

► 09.05.2017

Firmware

- V3.100 release
- Added new feature, Write Triggering, to control when service object writes are triggered when values are written to the database.
- Added enhancement to Modbus RTU Master driver's Group Multiple Writes setting to allow always grouping writes for entire service object.
- Added fail-safe timeout functionality to BACnet MS/TP Server driver.
- Added the Fail-safe Timeout protocol-specific network configuration parameter for BACnet MS/TP Server.
- Fixed issue with timeout detection in all slave/server drivers where a timeout could take twice as long under certain circumstances.
- Improved behavior of Value Change Detection database logic operation when using an enable trigger.
- Fixed issue in all master/client drivers that group multiple write requests into a single packet where requests may be split up after a single write within a service object even though multiple values change simultaneously.

Datasheet version

- September 5, 2017

► 07.19.2017

Firmware

- V3.000 release
- Added configurable Max Info Frames to BACnet MS/TP Client and Server to allow the device to send more than one packet each time it has the token.
- Added support to BACnet MS/TP Client and Server to allow writing to the device's Object Name, Object Identifier, and Max Info Frames properties over the BACnet network.
- Added support for Pulse Frequency Detection and changed the Pulse Counter I/O type to Pulse Input.
- Added floating point data type support and multiplier and offset scaling to the Pulse Input I/O type.
- Changed the Pulse Counter "Pin Change" mode option to "Any Edge".



- Improved pulse detection and debouncing algorithms for the Pulse Input I/O type to reduce CPU overhead and protect against interrupt overload.
- Added the Contact Style selection setting to the Digital Input and Pulse Input I/O types.
- Fixed issue with multiplier and offset scaling for GPIO objects where the selected data type affected the result.
- Added new feature to rapidly flash the status LED green when the device's Run Mode is in Configuration Mode to indicate parameters are being synchronized with the host.
- Added support for performing a write for all service objects mapped to network configuration parameters or persistent user parameters upon startup when the host port is configured as a master.
- Added support to all slave/server drivers to signal when communications is restored after a timeout occurs.
- Added a new Status Code, NETWORK_COM_ERROR, to signify when a network timeout is active.
- Added Macurco Modbus driver.
- Improved timeout detection in all slave/server drivers to account for receive errors and packets not intended for the device.
- Fixed issues with detecting leading space characters for fixed-length decimal values in Generic Serial driver Database Data.
- Changed Modbus RTU Sniffer gap time detection from 4 characters to 3 to account for devices that use an exact 3.5 character gap time.
- Added feature to Modbus RTU Sniffer driver to detect when the master is no longer sending requests after a specified timeout time and trigger a timeout event to apply fail-safe values.
- Changed how unused communication and I/O pins are defaulted when unused.

▶ 12.12.2016

Firmware

- V2.500 release
- Added support for port diagnostics byte counters.
- Added support for custom control of the status LED.

▶ 10.28.2016

Firmware

- V2.400 release
- Fixed issue in FLN Slave where writes to LDO's would not apply the bitmask properly.
- Optimized startup routines to decrease boot time.
- Fixed issue with DMX-512 Slave where receive errors could not be detected on the first received character.
- Fixed issue with DMX-512 Slave where receive errors in irrelevant characters caused the packet to be ignored.
- Improved Generic Serial driver's detection of variable length database data for ASCII decimal numbers with leading '+' or '-' characters.



► 09.15.2016

Firmware

- V2.300 release
- Changed the encoding of the Firmware Version network configuration parameter from 0xMMmm, where M is the major revision and m is the minor revision to FW_VERSION × 1,000, where FW_VERSION is the full version, such as 2.300.
- Added support to Generic Serial driver for handling leading '+' characters for ASCII decimal numbers.

Datasheet version

- September 15, 2016

► 08.15.2016

Firmware

- V2.200 release
- Added support to BACnet MS/TP Client and Server so that the APDU Timeout, Number of APDU Retries, and Max Master property values set over the network are persistent across reboots.
- Added support for time and date information in BACnet MS/TP Client and Server by utilizing an externally-provided real-time clock mapped into the device's database.
- Fixed issues with using the USB Virtual COM port with Windows 10.
- Added support for 7 data bits to the USB Pass-Through Mode.
- The device no longer goes into an error/warning state when Host - Network Serial Pass-Through mode is active.
- Corrected issues in device information when no configuration file is loaded on the device.

Datasheet version

- August 1, 2016

► 06.15.2016

Firmware

- V2.101 release
- Fixed issue where the serial driver would not detect errors on the first byte of a packet.
- Fixed issue with Generic Serial drivers where transactions with a large amount of variable sized packet data objects could cause the device to hang.
- Added support for the Database Matched Byte packet data object to Generic Serial drivers.



► 05.11.2016

Firmware

- V2.100 release
- Doubled the maximum supported configuration file size.
- Added support for a configurable Product ID.
- Added detection of non-configured protocol values in the Network Configuration Parameters' Protocol parameter so that the device now goes into the Invalid Configuration error state.
- Fixed issues with FLN and BACnet drivers when no objects are configured.

► 03.01.2016

Firmware

- V2.000 release
- Increased Object Memory by 50%.
- Added Persistent User Parameters
- Added support for PWM Modulation Mode, allowing the PWM output to modulate either Duty Cycle or Frequency.
- Added Generic Serial Master protocol.
- Added Generic Serial Slave protocol.
- Added Host - Network Pass-Through protocol.
- Added support for Internal Float (ADF), Internal Integer (ADI), and Internal Byte (BD) object types to Metasys N2 Slave.
- Modified Siemens FLN Slave driver's interpretation of non-zero intercept values so that the physical value sent on the network matches the database value for LAI and LAO points.
- Fixed USB connection issue where the device is sometimes not detected by the USB host when plugging in the USB cable to an already powered device.
- Fixed issue where writing 0xFFFF to a Network Configuration Parameter would reinitialize them from the configuration file upon resetting.
- BACnet BTL Certification changes
 - Added data type checks to Present Value writes so that only the proper data type is allowed.
 - Added support for configurable APDU Timeout.
 - Added support for configurable Number of APDU Retries.
 - Added support for APDU retries for confirmed requests.
 - Made the following device properties network writable: APDU Timeout, Number of APDU Retries, and Max Master.
 - Fixed issue with APDU Timeout timer where the timer started before the request was transmitted on the network.
 - Added support for the Reliability property in all supported object types.
 - Added support for configurable Number of States for Multi-state objects.
 - Added support for Offset by One option for Multi-state objects for both Client and Server.
 - Changed behavior of Multi-state Objects' Present Value property so that it cannot go outside of the range 1 - Number of States. If the database value is out of that range,



the FAULT Status Flag is set and the Reliability will be either Under Range or Over Range.

- Increased Vendor Name and Model Name OEM Setting string to support up to 32 characters.
- Added error code when accessing Priority Array and Relinquish Default properties for virtual objects, because these properties are not supported.
- Added feature to BACnet client to detect if a server device is no longer online and begin transmitting Who-Is requests to it instead of continuing to send read or write requests.
- Removed support for 4800 baud rate, since the BACnet specification states the minimum is 9600.
- Updated Revision to 12.
- Updated Object Types Supported Device object property.
- Fixed Number of States datatype for Multi-state objects.
- Improved error handling and error responses for error conditions when handling all packets.
- Fixed issue with the ReadPropertyMultiple ALL properties for the Device object.
- Corrected the properties reported for ReadPropertyMultiple ALL, OPTIONAL, and REQUIRED for all objects.
- Fixed issue when reading a Device object property using the wildcard instance number where the Object ID in the response used the wildcard instance number instead of the device's actual instance number.
- Increased MS/TP buffer size to 501 resulting in a new Maximum APDU size of 480.
- Fixed NPoll token count from 52 to 50.
- Added password to ReinitializeDevice.
- Fixed issue where device would respond to Confirmed Broadcast Request packets.
- Fixed issue where the device would ignore Data Expecting Reply packets targeted to the broadcast address.
- Fixed issue where the device would not properly ignore packets not for us by adding the Skip Data state to the receive state machine.
- Fixed EventCount handling error in MS/TP Master Node State Machine as described in addendum 135-2004d-8.
- Fixed poll for master to self issue in the DONE_WITH_TOKEN and PASS_TOKEN states.
- Added support to SubscribeCOV for the situation where the Lifetime argument is omitted from the request and should be assumed to be 0 (indefinite lifetime).
- Fixed issue where a COV could be issued after the COV has expired.
- Added support to initiate a COV notification after receiving a subscribe COV request.
- Fixed issue with reading the ACTIVE_COV_SUBSCRIPTIONS property of the device object.
- Fixed issue with reading the DEVICE_ADDRESS_BINDINGS property of the device object.
- Fixed issues with configured Relinquish Default value data type conversion.
- Fixed issue with Subscribe COV requests' Lifetime parameter not supporting the full Unsigned range.
- Fixed error code returned when a Subscribe COV request is received for the Device object.



- Fixed issue with DeviceCommunicationControl Time Duration timer not supporting the full Unsigned range.
- Fixed error code returned when a ReinitializeDevice request is received after a DeviceCommunicationControl DISABLE request is received.
- Fixed issue with COV Increment property's internal "unused" signifier value.
- Set maximum limit on Multi-state Number Of States property so that the internal reserved NULL value cannot be used.
- Added error reporting for BACnet Client when a Diagnostics object is used for Multi-state objects that have an invalid value.
- Fixed implementation of Device Instance wildcard value of 4194303 to be interpreted as if the device instance matches.
- Optimized performance for scenarios where the device is connected to a live BACnet network while powered on.
- Relaxed MS/TP timing parameters to ensure the specified times are never violated.

Datasheet version

- March 1, 2016

▶ **04.01.2015**

Firmware

- V1.300 release
- Add Inverted, Auto Reset, and Bitmask trigger options to database logic enable triggers.
- Added Bit Copy, Indirect Copy, Flag Test & Set, Value Change Detection, Multiplexer, and Byte Reverse database logic operations.
- Fixed issue where received bytes could be dropped during critical sections when the receiver is disabled.
- Added Protocol Format setting for the USB Serial Sniffer Settings protocol.
- Added PWM Frequency setting to GPIO Analog (PWM) Outputs.
- Added error code response to USB communications to prevent pipe stalls.
- Fixed packet corruption issue in USB serial sniffer when sniffer buffer overflows occur.
- Improved compiler optimizations.

Datasheet version

- April 1, 2015

▶ **10.30.2014**

Firmware

- V1.202 release
- Changed BACnet MS/TP Client static device destination address limit to 254 to support MS/TP slave-only addresses.
- Fixed issue where USB task may not be running if a fatal error occurs during startup.
- Added support for I/O objects mapped to configuration memory.



- Added support for timeout objects mapped to configuration memory.

Datasheet version

- October 30, 2014

▶ **08.22.2014**

Firmware

- V1.201 release
- Optimized startup order of all tasks.
- Fixed issue when saving/restoring reserved configuration parameters.
- Fixed BACnet DeviceCommunicationControl service.
- Corrected BACnet Protocol_Services_Supported Device property flags.
- Added check in Modbus Slave to respond with an exception to requests spanning multiple incompatible register remaps.

Datasheet version

- September 2, 2014

▶ **08.05.2014**

Firmware

- V1.200 release
- Changed Run Mode configuration parameter Reset value to 65535 (0xFFFF) and redefined the value of 0 to be Startup mode.
- Added floating point as a native database data type.
- Added USB Virtual COM Port support.
- Added FLN Master protocol.
- Added Toshiba Computer Link Master protocol.
- Added USB Serial Sniffer Settings protocol to use for packet capturing.
- Added Trigonometric Operations to Database Logic.
- Added Random operation to Database Logic.
- Changed I/O and Database Logic to run on startup instead of after the Run Mode parameter is set to Running.
- Fixed issue where writing to FLN LDO points fails.
- Improved SPI error handling when an invalid number of bits are clocked.
- Added ability for unused host port pins to be used as GPIO pins 6 - 9.
- Added configurable fields for Vendor ID, Vendor Name, and Model Name to BACnet MS/TP drivers.
- Added ability to relinquish written values in BACnet Client.
- Added write support for COV Increment property for BACnet Analog objects and added a configuration setting.
- Fixed COV checking for BACnet Multi-state objects.



- Fixed protocol configuration parameters for BACnet Client.
- Removed 0xFF byte pad in BACnet MS/TP packets.
- Fixed issue where internal pull up resistor was not enabled if GPIO pin is configured for pulse counter only.
- Changed GPIO Analog Offset field to a floating point number from an unsigned integer.
- Fixed issue where GPIO Pulse Counter would not operate in conjunction with Analog Input functionality on the same pin.
- Improved packet handling for DMX-512 Slave driver.
- Fixed issues in M-Bus Master driver when decoding and encoding string values.
- Fixed issues when Database Logic is used to update configuration parameters.
- Fixed issue with BACnet which could cause a duplicate packet to be sent 40 bit times after the first.
- Fixed issue in BACnet where the first reply to a poll for master was ignored if the last packet received was a partial packet.
- Changed I/O Analog Offset field to a floating point number from an integer.
- Fixed issue in Modbus when converting negative 32-bit integer values to floating point.
- Changed firmware revision string format.
- Various code optimizations

Datasheet version

- September 2, 2014

▶ **11.18.2013**

Firmware

- V1.104.00 release
- Added 6 parameters to EnGenius driver
- Added support for older EnGenius firmware
- Fixed issue with Debounce Filter and Hysteresis Filter when using an enable trigger.

Datasheet version

- October 1, 2013

▶ **09.27.2013**

Firmware

- V1.103.00 release
- Disabled internal pull-down resistors when GPIO is configured for Digital Output, Analog Input, or PWM Output.
- Added operation type to Not, And, Or, and Exclusive Or operations to select bitwise or logical operations.
- Added a floating point multiplier field to database logic inputs and output.
- Changed internal database logic data type to double when performing operations.



- Changed the data type of database logic constant values to double.
- Database logic bug fixes.

Datasheet version

- September 3, 2013

▶ **08.29.2013**

Firmware

- V1.102.00 release
- Added Exponential, Root, and Logarithm database logic operations.
- Added rounding to database logic operations which require it.
- Added support for base e (natural log, exponential) operations.
- Added SPI Slave support.
- Updated debounce algorithm for pulse counter inputs.

Datasheet version

- September 3, 2013

▶ **08.05.2013**

Firmware

- V1.101.00 release
- Added debounce time to pulse counter.
- Added Modulo database logic operation.

Specifications version

- May 31, 2013

▶ **07.31.2013**

Firmware

- V1.100.00 release
- Fixed issue where BACnet driver would communicate even if there is traffic at a different baud rate.
- Added database logic.
- Added pulse counter to the I/O objects.
- Fixed Metasys Master issue where binary values were not updating correctly.

Specifications version

- May 31, 2013



▶ **05.21.2013**

Firmware

- V1.008.00 release
- Added additional protocol-specific configuration parameter checks.
- Improved Modbus RTU Master response checking.
- Added USB function to read the device's serial number.
- Added licensing support.
- Removed limitations on configuration memory writes.
- Minor bug fixes.

Specifications version

- January 2, 2013

▶ **04.03.2013**

Firmware

- V1.004.00 release
- Added VMA device support for Metasys Master driver.
- Minor bug fixes.

Specifications version

- January 2, 2013

▶ **03.26.2013**

Firmware

- V1.002.00 release
- Added protocol configuration parameters.
- Switched to new version format and added new USB function to read the new format.

Specifications version

- January 2, 2013

▶ **02.26.2013**

Firmware

- V1.000 initial release

Specifications version

- January 2, 2013