

## XLTR-1000 Version Info

### } **01.18.2012**

#### Firmware

- Chillgard V2.400 release
- A.O. Smith V2.300 release
- Added A.O. Smith AIN and PDNP drivers
- Added support for different types of scaling for the concentration values including new % units in Chillgard
- Added support for more gas types in Chillgard

#### User's manual version

- 10756 January 15, 2012

### } **08.15.2011**

#### Firmware

- V2.300 release
- Added DMX-512 Master and Slave drivers
- Added M-Bus Master driver
- Added function code 05 (Force Single Coil) to Modbus Master driver
- Increased Service Object memory usage

#### User's manual version

- 10756 August 15, 2011

### } **02.01.2011**

#### Firmware

- V2.200 release.
- Added MSA Chillgard driver.
- Added Metasys N2 Master driver.
- Added Siemens FLN driver.
- Added TCS Basys driver.
- Fixed Modbus Master bug when Floating Point is checked and multiplier is 1, the value is now correctly converted as a floating point number.
- Improved accuracy of Modbus multiplier scaling.
- Updated Metasys Slave driver so that it won't reset the object configuration upon receiving the "F" command.
- Fixed Modbus Slave remap object issues.
- Fixed FLN bug where LDO writes were not updated using read-modify-write.
- Fixed FLN bug where LAO's and LDO's were not updated before a COV check when COVs were not enabled.

#### User's manual version

- 10756 February 1, 2011

## } **03.01.2010**

### Firmware

- V2.100 release.
- Added Sullair master driver.
- Added Modbus sniffer driver.
- Added Enron/Daniel 32-bit Modbus extension to Modbus master and slave drivers.
- In Modbus RTU slave driver, holding registers and input registers can now be remapped independently, and can have multipliers applied.
- Decreased object memory usage for BACnet objects in BACnet MS/TP server driver.
- BACnet MS/TP client driver now sends "Who-Is" for all configured destination devices on startup, not just statically-bound ones.
- Improved efficiency of service object handling in BACnet MS/TP client driver.
- Fixed "Poll-For-Master to self" bug in BACnet MS/TP drivers.
- Fixed "multiply by 1 rounding" issues.

### User's manual version

- 10756 March 1, 2010

## } **12.30.2009**

### Firmware

- No change (still V2.000)

### User's manual version

- 10756 December 30, 2009: minor updates and improvements only

## } **12.01.2009**

### Firmware

- V2.000 initial release.

### User's manual version

- 10756 December 1, 2009